

Annual Drinking Water Quality Report for 2023
WILLOW BROOK ESTATES, LLC
12319 RT 9W
WEST COXSACKIE, NY 12192
(Public Water Supply ID# NY1906316)

INTRODUCTION

To comply with State regulations, Willow Brook Estates, LLC, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Rich or Rob Slater, owners at 518-731-6492. We want you to be informed about your drinking water. If you want to learn more, please feel free to give us a call or stop by the office during regular business hours.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to the drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells.

The susceptibility rating is an estimate of the potential for contamination of the source water; it does not mean that the water delivered to consumers is or will become contaminated. See the section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected.

As mentioned before, our water is derived from two drilled wells. The source water assessment has rated these wells as having a medium-high susceptibility to microbial and medium susceptibility to nitrates. These ratings are due primarily to the close proximity of low-intensity residential activities within the assessment area.

In addition, the wells draw from a confined aquifer that likely provides adequate protection from potential contamination. Our wells do not require disinfection as bacteriological water quality continues to be satisfactory. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted below.

Our water system serves approximately 251 people through 85 service connections. Our water source is two groundwater wells: groundwater is drawn from two 100-foot deep drilled wells located within the mobile home park on Rt 9W. The water is served raw with no treatment prior to distribution due to our approved water quality and disinfection waiver provided by the NYS Department of Health.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants may include total coliform, inorganic compounds, nitrate, nitrite, lead, and copper, volatile organic compounds, and radiological. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Oneonta District Office Health Department at 607-432-3911.

Table of Detected Contaminants

| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | Regulatory Limit (MCL, TT or AL) | MCLG | Likely Source of Contamination |
|--|------------------|----------------|----------------------------------|------------------|----------------------------------|------|---|
| Lead (Distribution) ² | NO | 12/31/2023 | 90% = 1.6 (Range) ND-3.2 | ug/l | AL= 15 | 15 | Corrosion of household plumbing systems; Erosion of natural deposits. |
| Copper (Distribution) ¹ | NO | 12/31/2023 | 90% = 0.03085 (Range) ND- 0.0341 | mg/l | AL=1.3 | 1.3 | Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives. |
| Arsenic (Well 1) | NO | 2/2/2023 | 4.2 | ug/l | MCL=10 | N/A | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Baruim (Well 1) | NO | 2/2/2023 | 0.0499 | mg/l | MCL=2 | 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Baruim (Well 2) | NO | 2/2/2023 | 0.0555 | mg/l | MCL=2 | 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Chromium (Well 1) | NO | 2/2/2023 | 2.1 | ug/l | MCL=100 | 100 | Discharge from steel and pulp mills; Erosion of natural deposits. |
| Chromium (Well 2) | NO | 2/2/2023 | 2.1 | ug/l | MCL=100 | 100 | Discharge from steel and pulp mills; Erosion of natural deposits. |
| Nickel (Well 1) | NO | 2/2/2023 | 0.0014 | mg/l | N/A | N/A | Naturally occurring. |
| Nickel (Well 2) | NO | 2/2/2023 | 0.0012 | mg/l | N/A | N/A | Naturally occurring. |
| Nitrate (Well 2) | NO | 2/2/2023 | 0.088 | mg/l | MCL= 10 | 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Gross alpha activity (including radium – 226 but excluding radon and uranium) (well 1) | NO | 2/2/2023 | 1.72 | PCi/L | MCL=0 | 15 | Erosion of natural deposits |

Footnotes:

1) The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected in your water system. In this case, 5 samples were collected at your water system, and the 90th percentile value (0.20 mg/l) is the second highest value. The action level for copper was **not** exceeded at any of the sites tested.

2) The level presented represents the 90th percentile of the 5 sites tested. In this case, 5 samples were collected at your water system, and the 90th percentile value (1.6 ug/l) is the highest value. The action level for lead was **not** exceeded at any of the sites tested.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Willow Brook Estates is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Willow Brook Estates (Rich or Rob Slater). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2023, our system was in compliance with applicable State drinking water operating, monitoring, and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water meets or exceeds state and federal regulations, some people may be more vulnerable to diseases caused by microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their healthcare provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia, and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our residents. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our residents help us protect our water sources, which are the heart of our community. Please call our office if you have questions.